

# NABERS Energy Rating Report

This report provides more information about your NABERS Energy Rating and greenhouse gas emissions. It explains how the data for your NABERS Energy Rating can be used to meet mandatory and voluntary reporting requirements.

These NABERS Energy Rating details are for

THE TRUSTEE FOR SCHWARTZ FAMILY TRUST

Mercure Canberra

39 Limestone Avenue

BRADDON ACT 2612

Rating number

HTEN42205

Valid until

12 October 2026

Rating period

1/7/24 - 30/6/25

## NABERS Energy Rating




Rating progress metric<sup>1</sup>: 3.6 stars

Building Type	Hotel
Rated guest rooms	128.95
Rated laundry serviced rooms	110.58
Rated external laundry serviced rooms	0.00
Function room seats	143.65
Surface area of heated pools	0.00 m <sup>2</sup>
<b>Rated electricity</b>	<b>919,500.00 kWh</b>
<b>Rated gas and LPG</b>	<b>3,193,249.28 MJ</b>
<b>Rated diesel</b>	<b>0.00 L</b>

<sup>1</sup> The rating progress metric indicates where a rating sits between a whole or half-star increment.

# NABERS Renewable Energy Indicator

■ Gas ■ Non-renewable electricity ■ RET/State targets



	Quantity	% of total site energy
<b>Renewable electricity</b>		
Onsite renewable electricity	0.00 kWh	0.0 %
RET <sup>1</sup> and State/Territory targets	907,735.94 kWh	50.2 %
GreenPower	0.00 kWh	0.0 %
Other voluntary purchases <sup>2</sup>	0.00 kWh	0.0 %
<b>Total renewable electricity</b>	<b>907,735.94 kWh</b>	<b>50.2 %</b>
<b>Non-renewable energy</b>		
Non-renewable electricity	11,764.06 kWh	0.7 %
Gas and LPG	3,193,249.28 MJ	49.1 %
Diesel	0.00 L	0.0 %

## Your NABERS Energy Rating is 3.5 stars and your greenhouse gas emissions<sup>3</sup> are

Total greenhouse gas emissions (scope 1 & 2)	771,418.00 Kg CO <sub>2</sub> -e p.a.	①
Total greenhouse gas emissions (full fuel cycle - scope 1, 2 & 3)	850,030.00 Kg CO <sub>2</sub> -e p.a.	③
Greenhouse gas intensity (scope 1 & 2)	5,982.00 Kg CO <sub>2</sub> -e/room p.a.	④
Greenhouse gas intensity (full fuel cycle - scope 1, 2 & 3)	6,592.00 Kg CO <sub>2</sub> -e/room p.a.	⑤
Predicted average intensity (full fuel cycle - scope 1, 2 & 3) <sup>4</sup>	8,727.00 Kg CO <sub>2</sub> -e/room p.a.	⑥

Energy intensity: 50,434.69 MJ/room p.a. ⑦

<sup>1</sup> RET stands for Renewable Energy Target

<sup>2</sup> Includes voluntarily surrendered LGCs from both electricity generated offsite, and from electricity generated onsite that is exported to the grid.

<sup>3</sup> Greenhouse gas emissions for this rating have been calculated applying emissions factors from the NGA factor 2024 edition. The location based electricity accounting method was used.

<sup>4</sup> The predicted emissions for a comparable building at 3 stars. This is a legacy value that will soon be excluded from the report. Contact NABERS with any concerns.

# How to use your NABERS Energy rating details

The table below explains how you can use the data in this report for mandatory and voluntary reporting requirements. For each reporting requirement, use the number(s) in the right column to identify the correct data to be used from 'Your rating details' table in the first page of this report.

---

## Voluntary scheme and reporting

### For corporate annual reporting of energy of use and carbon footprint

7

Organisations are encouraged to report their energy use and full life cycle greenhouse gas emissions (scope 1, 2 & 3) in their annual report to capture a more comprehensive picture of emissions attributed to its activities.

5

---

### For National Carbon Offset Standard

6

This is a voluntary standard for businesses to use in becoming carbon neutral or developing carbon neutral products. For more information about the NCOS program, see [www.climatechange.gov.au](http://www.climatechange.gov.au)

---